

NOTICE AND NECESSARY INFORMATION (NANI)

This form is to assist compliance with the bulk sewage (biosolids) notification requirements [503.12(f)]. Please note, however, that if the biosolids meet the exceptional quality criteria, then the notification requirements do not apply. This form can be used by preparers of biosolids to transmit information to land appliers and also by land appliers to transmit information to land owners or lease holders.

Facility and Biosolids Type:: GWRP Compliance

Monitoring Period: 9/1/14 To: 10/31/14

Name	Concentration (mg/Kg) Dry Weight	Pollutant Concentrations (Table 3, 40 CFR 503.13) Monthly Average	Ceiling Concentrations* (Table 1, 40 CFR 503.13) Daily Maximum
Arsenic	< 13.0	41	75
Cadmium	2.50	39	85
Chromium	75.0	1200	3000
Copper	360	1500	4300
Lead	11.0	300	840
Mercury	0.69	17	57
Molybdenum	17.0	N/A**	75
Nickel	33.0	420	420
Nitrogen Concen	48600	N/A	N/A
Selenium	< 13.0	36	100
Zinc	800	2800	7500

* Biosolids may not be land applied if any pollutant exceeds these values.

** EPA has temporarily removed molybdenum limits from Table 3, Table 2 and Table

B. Pathogen Reduction (40CFR 503.32) -- Please indicate the level achieved

☐ Class A

☒ Class B

C. Vector Attraction Reduction (40CFR 503.33) -- Please indicate the option performed

☒ Option 1

☐ Option 2

☐ Option 3

☐ Option 4

☐ Option 5

☐ Option 6


☐ Option 7

☐ Option 8

☐ No vector attraction reduction options were performed

D. Certification

I certify, under penalty of law, that the information that will be used to determine compliance with the Class B pathogen requirements in §503.32(b) and the vector attraction reduction requirement in §503.33(b)(1) was prepared under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate this information. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment.

A. Name and Official Title Jennifer Hetherington, Wastewater Compliance Specialist	B. Area Code and Telephone Number 480-644-3890
C. Signature 	D. Date Signed 10/20/14

Laboratory Sample ID: 140919005